

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 01:10 pm

PWS ID: UTAH29006 **Name:** HOOPER WATER IMPROVEMENT DISTRICT
Legal Contact: HOOPER WATER IMPROVE DIST **Rating:** Approved
 STEVEN SCOTT CHRISTIANSEN **Rating Date:** 09/09/1981
Address: PO BOX 217 **Activity Status:** Active
 HOOPER, UT 84315
Phone Number: 801-985-1991
City Served (Area):
County: WEBER COUNTY

System Type: Community **Last Inv Update:** 05/14/2009 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 11/17/2010 **Total Dsgn Cap:**
Population: 16,520 **Surveyor:** SHERRIE WATERS **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	CHRISTIANSEN, STEVEN SCOTT		801-985-1991	801-643-5934	scotthwid@qwestoffice.net

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Metered	0	4,189
			4,189 Total Svc Connections

Storage

Total Storage: 4,750,000 GAL **Number of Units:** 3 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	2 MG SOUTH TANK	Ground	2,000,000 GAL	Steel		A	NO
ST002	2 MG NORTH TANK	Ground	2,000,000 GAL	Steel		A	NO
ST003	400 S TANK	Ground	750,000 GAL	Steel		A	NO

Pumping Stations

Facility No	Facility Name	Activity Status	Capacity	Avail	Emerg Power	Operating Category	Total Dynamic Head
PF001	PUMP STATION 1	P		P			

Distribution System

Pump Type	Total Dyn Head ft H2O P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	WELL #1 5450 SOUTH	Active	WL	16		2,000 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS002	ABANDONED-CEMENTED-C	Inactive	WL	6			Yes	GW	Seasonal		
WS003	UTAH29023 WEBER BASIN \	Active	CC				No	SW	Permanent	1/1 to 12/31	
WS004	WELL #3 1800 N 4200 W	Active	WL	14	1500 GPM		Yes	GW	Permanent	1/1 to 12/31	

*Reports measured flow for wells, approved design capacity for all other sources.

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS005	WELL #2 4000 SOUTH	Active	WL		2350 GPM		Yes	GW	Permanent	1/1 to 12/31	

**Reports measured flow for wells, approved design capacity for all other sources.*